



PURCHASE REQUEST

CALUMPIT WATER DISTRICT

Department:	Engineering & Operations Department	PR No.:	2016-11-01
Section:		Date:	7-Nov-16

STOCK NO.	UNIT	ITEM DESCRIPTION	QUANTITY	ESTIMATED UNIT COST	ESTIMATED TOTAL COST
	unit	<p>Lot 1: Franklin Motor, <i>PF</i> Submersible Motor 6" diameter, hermetically sealed winding, kingsburry type water lubricated thrust bearing, corrosion resistant, utilizing stainless steel and splined shaft, sand fighter slinger, built in lightning arrester rated <i>Grundfos SP30-5 PF</i> 10HP, 230V, 3 phase, 60 Hertz, coupled to Submersible Pump, rated to deliver 9 LPS at 60 meters TDH, built in check valve, 3" NPT discharge with sand handling capability. (Spare Pump and Motor for Gardenville or Green Plains Pumping Stations)</p> <p>Lot 2: Franklin Submersible Motor 4" diameter, hermetically sealed winding, kingsburry type water lubricated thrust bearing, corrosion resistant, utilizing stainless steel and splined shaft, sand fighter slinger, built in lightning arrester rated <i>Grundfos SP14A-6 PF</i> 5HP, 230V, 3 phase, 60 Hertz, coupled to Submersible Pump, rated to deliver 4 LPS at 60 meters TDH, built in check valve, 2" NPT discharge with sand handling capability. (Spare Pump and Motor for Green Plains Booster Pump)</p> <p>Lot 3: (motor only) Franklin <i>PF</i> Submersible Motor 4" diameter, hermetically sealed winding, kingsburry type water lubricated thrust bearing, corrosion resistant, utilizing stainless steel and splined shaft, sand fighter slinger, built in lightning arrester rated <i>4lps</i> 3HP, 230V, 1 phase, 60 Hertz. (Spare Motor for Meysulao Sapa Pumping Station)</p>			0.

Purpose: Spare Pumps and Motors.

Signature: Print Name Designation	Requested by:  <hr/> EDILBERTO P. SANTOS Department Manager, EOD	Approved by:  <hr/> Engr. RONNIE B. LARGADO General Manager
---	---	--



REPUBLIC OF THE PHILIPPINES

CALUMPIT WATER DISTRICT

Bids and Awards Committee

M. Serrano St., Corazon Calumpit, Bulacan

Tel No.: (044) 675-1453

Telefax: (044) 202-5125

Email address: calumpitwd@yahoo.com

BAC RESOLUTION NO. 2016-215

**Re: Supply and Delivery of Various Pump & Motor
(spare pump & motor for various pump stations)**

(Please see attached purchase request for item description)

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2016-11-011; Supply and Delivery of Various Pump & Motor (spare pump & motor for various pump stations);

WHEREAS, the members of the BAC agreed to adopt Section 53.9, Article XVI of RA 9184, which states the use of Small Value Procurement, a method of procurement where the procurement does not fall under Shopping in Section 52 of this IRR and the amount involved does not exceed the thresholds prescribed in Annex "H" of this IRR.(a);


53.9.1 The procuring entity shall draw up a list of at least three (3) suppliers, contractors, or consultants of known qualifications which will be invited to submit proposals, in the case of goods and infrastructure projects, or curriculum vitae, in the case of consulting services.(a)

NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;

1. To recommend the use of Small Value Procurement for Purchase Request No. 2016-11-011.
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing findings;

RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, this 1st of December 2016.



EDILBERTO P. SANTOS
BAC Vice Chairman


RONALDO DC. TANTOCO
BAC Member


ELVIRA M. RAÑOPA
BAC Chairman


EMELY E. ECHEVARRIA
BAC Member


ESPERANZA L. CORTEZ
BAC Member


Engr. RONNIE B. LARGADO
General Manager, Head of the Procuring Entity
Approved on Dec. 01, 2016