

BAC RESOLUTION NO. 2018-067

Re: Supply and Delivery of Various Pipes to be used for the Installation of New Transmission Line for Bulacan Bulk Water – Phase 1 (Partial Implementation)

(Please see attached purchase request for item description)

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2018-04-005; Supply and delivery of various pipes to be used for the installation of new transmission line for Bulacan Bulk Water – Phase 1 (partial implementation);

WHEREAS, the members of the BAC agreed to adopt Section 52, Article XVI of RA 9184, which states the use of Shopping, a method of procurement of goods whereby the Procuring Entity simply requests for the submission of price quotations for readily available off-the-shelf goods or ordinary/regular equipment to be procured directly from suppliers of known qualifications. This method of procurement shall be employed in any of the following cases:

- a) When there is an unforeseen contingency requiring immediate purchase: *Provided, however,* that the amount shall not exceed the thresholds prescribed in Annex “H” of this IRR.
- b) Procurement of ordinary or regular office supplies and equipment not available in the Procurement Service involving an amount not exceeding the thresholds prescribed in Annex “H” of this IRR.

NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;

1. To recommend the use of Shopping for Purchase Request No. 2018-04-005.
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing findings;

RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, this 6th of April 2018.

EDIBERTO P. SANTOS
BAC Vice Chairman

EMELY E. ECHEVARRIA
BAC Chairman

RONALDO DC. TANTOCO
BAC Member

MARICAR DC. JOAQUIN
BAC Member


ANTONIO M. CRUZ
BAC Member


ESPERANZA L. CORTEZ
BAC Member

Engr. ROMNIE B. LARGADO
General Manager, Head of the Procuring Entity
Approved on 04/11/18

Office/Section : Engineering Department		PR No.: 2018-09-005 Responsibility Center Code :	Date: 3-Apr-18		
Stock/ Property No.	Unit	Item Description	Quantity	Unit Cost	Total Cost
	pcs	100 mm x 6.0 m uPVC Pipe Class 150 with RR	147	2,900.00	426,300.00
		<p>uPVC PIPE SPECIFICATION:</p> <p>NOMINAL OUTSIDE DIAMETER : 110MM DIAMETER TOLERANCE : 110.40 MM MINIMUM SOCKET DEPTH : 114 (E) EFFECTIVE LENGTH : 6000MM WALL THICKNESS / PNS 65: 1993 : SERIES 8 / CLASS 150 (MIN.: 6.3 / MAX.: 7.13) MATERIALS : THE MATERIALS FROM WHICH THE PIPES ARE MADE SHALL BE POLYVINYL CHLORIDE AND SHALL CONFORM TO PNS65 1993</p> <p>COLOR : POLYVINYL CHLORIDE PIPE SHALL BE EXTRUDED BLUE NEAREST TO RAL 5012</p> <p>TEST PROCEDURES : AS SPECIFIED IN PNS 65: 1993</p> <p>JOINTS : ELASTOMERIC SEALING RING TYPE JOINTS SHALL BE USED FOR SIZES 63MM UP TO 500MM. THE ELASTOMERIC SEALING RING SHALL CONFORM TO PNS1008 / ISO 4633</p> <p>MARKINGS : THE PIPE SHALL BE CLEARLY MARKED WITH THE FOLLOWING INFORMATION SPACED AT INTERNALS OF NOT MORE THAN 1 METER</p> <p>1. THE MANUFACTURER'S NAME OR TRADEMARK 2. NAME OF PRODUCT 3. NOMINAL OUTSIDE DIAMETER IN MM 4. SERIES NUMBER SAND/OR NOMINAL PRESSURE MPA 5. THE WORDS 'MADE IN THE PHILIPPINES' 6. THE WORDS 'FOR POTABLE WATER'</p> <p>TECHNICAL REQUIREMENT FOR uPVC PIPES:</p> <ul style="list-style-type: none"> - MANUFACTURER'S ISO CERTIFICATION COVERING THE ACTIVITIES/ PROCESS IN THE MANUFACTURER OF PVC PIPES ISSUED BY CERTIFICATION BODY IN THE PHILIPPINES (ISO 9001:2008 AND ISO 14001:2004 CERTIFICATION) - LWUA ACCREDITATION CERTIFICATE - CERTIFICATE OF DEALERSHIP - BROCHURE - SHOP DRAWING - PNS 65:1993 CERTIFICATION - COMPLIANCE FOR RUBBER GASKET MILL CERTIFICATE 			
	pcs	75 mm x 6.0 m uPVC Pipe Class 150 with RR	105	1,950.00	204,750.00
		<p>uPVC PIPE SPECIFICATION:</p> <p>NOMINAL OUTSIDE DIAMETER : 75MM DIAMETER TOLERANCE : 75.30 MM MINIMUM SOCKET DEPTH : 101 (E) EFFECTIVE LENGTH : 6000MM WALL THICKNESS / PNS 65: 1993 : SERIES 8 / CLASS 150 (MIN.: 4.3 / MAX.: 4.93) MATERIALS : THE MATERIALS FROM WHICH THE PIPES ARE MADE SHALL BE POLYVINYL CHLORIDE AND SHALL CONFORM TO PNS65 1993</p> <p>COLOR : POLYVINYL CHLORIDE PIPE SHALL BE EXTRUDED BLUE NEAREST TO RAL 5012</p> <p>TEST PROCEDURES : AS SPECIFIED IN PNS 65: 1993</p> <p>JOINTS : ELASTOMERIC SEALING RING TYPE JOINTS SHALL BE USED FOR SIZES 63MM UP TO 500MM. THE ELASTOMERIC SEALING RING SHALL CONFORM TO PNS 1008 / ISO 4633</p> <p>MARKINGS : THE PIPE SHALL BE CLEARLY MARKED WITH THE FOLLOWING INFORMATION SPACED AT INTERNALS OF NOT MORE THAN 1 METER</p> <p>1. THE MANUFACTURER'S NAME OR TRADEMARK 2. NAME OF PRODUCT 3. NOMINAL OUTSIDE DIAMETER IN MM 4. SERIES NUMBER SAND/OR NOMINAL PRESSURE MPA 5. THE WORDS 'MADE IN THE PHILIPPINES' 6. THE WORDS 'FOR POTABLE WATER'</p> <p>TECHNICAL REQUIREMENT FOR uPVC PIPES:</p> <ul style="list-style-type: none"> - MANUFACTURER'S ISO CERTIFICATION COVERING THE ACTIVITIES/ PROCESS IN THE MANUFACTURER OF PVC PIPES ISSUED BY CERTIFICATION BODY IN THE PHILIPPINES (ISO 9001:2008 AND ISO 14001:2004 CERTIFICATION) - LWUA ACCREDITATION CERTIFICATE - CERTIFICATE OF DEALERSHIP - BROCHURE - SHOP DRAWING - PNS 65:1993 CERTIFICATION - COMPLIANCE FOR RUBBER GASKET MILL CERTIFICATE 			
			TOTAL		631,050.00

Purpose: Materials to be use for partial implementation of Installation of new Transmission Pipeline for Bulacan Bulk Water (phase 1)

Requested by:
Signature : 
Printed Name : **EDILBERTO P. SANTOS**

Approved by:

Engr. RONNIE B. LARGADO