



**BAC RESOLUTION NO. 2018-232**

**Re: Supply & Delivery of Various Fittings**  
**(to be carried on stock – for CSD & EDO use)**  
 (Please see attached purchase request for item description)

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2018-08-005; Supply & Delivery of Various Fittings (to be carried on stock – for CSD & EDO use);

WHEREAS, the members of the BAC agreed to adopt Section 52, Article XVI of RA 9184, which states the use of Shopping, a method of procurement of goods whereby the Procuring Entity simply requests for the submission of price quotations for readily available off-the-shelf goods or ordinary/regular equipment to be procured directly from suppliers of known qualifications. This method of procurement shall be employed in any of the following cases:

- a) When there is an unforeseen contingency requiring immediate purchase *Provided, however,* that the amount shall not exceed the thresholds prescribed in Annex "H" of this IRR.
- b) Procurement of ordinary or regular office supplies and equipment not available in the Procurement Service involving an amount not exceeding the thresholds prescribed in Annex "H" of this IRR.


NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;

1. To recommend the use of Shopping for Purchase Request No. 2018-08-005.
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing findings;

RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, the 30<sup>th</sup> of August 2018.

  
 EDILBERTO P. SANTOS  
 BAC Vice Chairman

  
 EMELY E. ECHEVARRIA  
 BAC Chairman

  
 RC NALDO DC. TANTOCO  
 BAC Member

  
 MARICAR DC. JOAQUIN  
 BAC Member

  
 ESPERANZA L. CORTEZ  
 BAC Member


Engr. RONME B. LARGADO  
 General Manager, Head of the Procuring Entity  
 Approved on \_\_\_\_\_

Entity Name: CALUMPIT WATER DISTRICT

Fund Cluster:

Office/Section :		PR No.: 2018-08- 005	Date: August 02, 2018		
Admin Department		Responsibility Center Code :			
Stock/ Property No.	Unit	Item Description	Quantity	Unit Cost	Total Cost
4193	pc	1/2" GI ST. ELBOW STD. SIZE	200		
4901	pc	1/2" GI PLUG STD. SIZE	300		
5501	pc	50mm CI SLEEVE TYPE COUPLING for PVC	20		
5935	pc	1/2" BRASS BALL VALVE with keywrench	300		
		NOTE :			
		For Brass Ball / Check Valve, a certification stating that the Brass fitting to be delivered should have a copper content of at least 65% supported by certificate for Chemical analysis from Metal Research and Development Center (MIRDC) or similar accredited Laboratory by the Philippine Accreditation Office within one (1) year prior to submission of quotation for brass fittings.			

Purpose: To be carried on stock (for CSD & EOD use).

Requested by:  8/3

Approved by:  08/02/18