



REPUBLIC OF THE PHILIPPINES
CALUMPIT WATER DISTRICT

Bids and Awards Committee
M. Serrano St., Corazon Calumpit, Bulacan
Tel No.: (044) 675-1453 / 913-0079
Email address: calumpitwd@yahoo.com

BAC RESOLUTION NO. 2019-093

Re: Supply & Delivery of 50mm FLOWMETER

(to be used for replacement of flow meter at Creekstone & Groove Subdivision)
(Please see attached purchase request for item description)

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2019-04-011; Supply & Delivery of 50mm FLOWMETER (to be used for replacement of flow meter at Creekstone & Groove Subdivision);

WHEREAS, the members of the BAC agreed to adopt Section 52, Article XVI of RA 9184, which states the use of Shopping, a method of procurement of goods whereby the Procuring Entity simply requests for the submission of price quotations for readily available off-the-shelf goods or ordinary/regular equipment to be procured directly from suppliers of known qualifications. This method of procurement shall be employed in any of the following cases:

- a) When there is an unforeseen contingency requiring immediate purchase: *Provided, however,* that the amount shall not exceed the thresholds prescribed in Annex "H" of this IRR.
- b) Procurement of ordinary or regular office supplies and equipment not available in the Procurement Service involving an amount not exceeding the thresholds prescribed in Annex "H" of this IRR.


NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;

1. To recommend the use of Shopping for Purchase Request No. 2019-04-011.
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing findings;


RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, this 25th of April 2019.



EDILBERTO P. SANTOS
BAC Vice Chairman



MARICAR D.C. JOAQUIN
BAC Member


Engr. RONNIE B. LARGADO
General Manager, Head of the Procuring Entity

Approved on 04/25/19


EMELY E. ECHEVARRIA
BAC Chairman


RONALDO D.C. TANTOCO
BAC Member


ESPERANZA E. CORTÉZ
BAC Member

PURCHASE REQUEST

Entity Name: CALUMPIT WATER DISTRICT


Fund Cluster:

Office/Section : Engineering Department		PR No.: 2019-04-011			Date: 12-Apr-19	
		Responsibility Center Code :				
Stock/ Property No.	Unit	Item Description	Quantity	Unit Cost	Total Cost	
	UNIT	50mm FLOW METER	2	55,000.00	110,000.00	
		SPECIFICATION:				
		GKM Helix 4000 Woltman cold potable type water meter				
		H4000 performance (forward flow) 50mm (2") Ø F/F Connecion				
		Dutile Iron Body, Epoxy Coated Body,Hard Surface Rotor Bearings				
		Tungsten carbide & Synthetic sapphire				
		PERMANENT FLOW: 50m ³ /hr				
		TRANSITIONAL FLOW: 1m ³ /hr				
		MINIMUM FLOW: (horizontal) 0.35m ³ /hr				
		MINIMUM FLOW: (vertical) 0.45m ³ /hr				
		STARTING FLOW: (approximately) 0.16m ³ /hr				
		MAXIMUM WATER TEMPERATURE: 50 deg C				
		MAXIMUM WORKING PRESSURE: 16 bars				
		MAXIMUM REGISTRATION: 1 millions of m ³				
		HEAD LOSS AT MAXIMUM FLOW: 0.05 bar				
		DIMENSION: Overall length (ISO) (A) 200/300mm				
		FLANGE DIAMETER: 166mm				
		WEIGHT ISO: 12.2/13.1 Kg				
				TOTAL	110,000.00	


Purpose: MATERIALS TO BE USED FOR REPLACEMENT OF FLOW METER AT CREEKSTONE AND GROOVE SUBDIVISION

Signature :
Printed Name :
Designation :

Requested by:


EDILBERTO P. SANTOS
 Department Manager B

Approved by:


Engr. RONNIE B. LARGADO
 General Manager