



**REPUBLIC OF THE PHILIPPINES
CALUMPIT WATER DISTRICT**

Bids and Awards Committee

M. Serrano St., Corazon Calumpit, Bulacan

Tel No.: (044) 675-1453 / 913-0079

Email address: calumpitwd@yahoo.com

BAC RESOLUTION NO. 2019-109

Re: Verification & Calibration of Pumping Stations' Electromagnetic Flow Meters

(for maintenance of electromagnetic flow meters)

(Please see attached purchase request for item description)

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2019-05-005; Verification & Calibration of Pumping Stations' Electromagnetic Flow Meters (for maintenance of electromagnetic flow meters);

WHEREAS, the members of the BAC agreed to adopt Section 53.9, Article XVI of RA 9184, which states the use of Small Value Procurement, a method of procurement of Goods, Infrastructure and Consulting Services where the amount involved does not exceed the thresholds prescribed in Annex "H" of this IRR: Provided, That in case of Goods, the procurement does not fall under shopping in Section 52 of this IRR.(a)

The BAC shall prepare and send the RFQs/RFPs to at least three (3) suppliers, contractors or consultants of known qualifications. This, notwithstanding, those who responded through any of the required postings shall be allowed to participate. Receipt of at least one (1) quotation is sufficient to proceed with the evaluation thereof.

NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;

1. To recommend the use of Small Value Procurement for Purchase Request No. 2019-05-005.
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing findings;


RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, this 15th of May 2019.


EDILBERTO P. SANTOS
BAC Vice Chairman


MARICAR DC JOAQUIN
BAC Member

Engr. RONNIE B. LARGADO
General Manager, Head of the Procuring Entity




EMELY E. ECHEVARRIA
BAC Chairman


RONALDO DC. TANTOCO
BAC Member


ESPERANZA L. CORTÉZ
BAC Member

Office/Section : Enng & Operations Dept.		PR No.: 2019-05-005 Responsibility Center Code :	Date: 6-May-19		
Stock/ Property No.	Unit	Item Description	Quantity	Unit Cost	Total Cost
	lot	VERIFICATION AND CALIBRATION OF ELECTROMAGNETIC FLOWMETERS OF THE FOLLOWING PUMP STATIONS:	1	320,880.00	320,880.00
		1. Balungao P.S			
		2. Corazon P.S			
		3. Caniogan P.S			
		4. Tata Pading P.S			
		5. Meysulao Sapa P.S			
		6. Danga P.S			
		7. Buguion P.S			
		8. Calizon P.S			
		9. Garden Ville P.S			
		10. Green Plains P.S			
		11. Northville IX P.S			
		12. Pungo P.S			
		13. San Jose P.S			
		14. Balungao Central P.S			
		15. Meysulao Riverside P.S			
		16. Iba Este P.S			
		17. Gatbuca P.S			
		DELIVERABLES:			
		A. Supply of Labor, Tools and Equipments for the check up, verification and calibration of Siemens Magflo Electromagnetic Flowmeter, Siemens Magflo Electronics and parts condition.			
		Note:			
		A.1. VERIFICATION is to check , measure and verify the integrity of actual condition of electronic and sensor signal, insulation and magnetism.			
		A.2. CALIBRATION is to ensure the accuracy aof the flowmeter . Should the meter found not in standard accuracy of 100% or within 98% to 102%, the device must be restored to its original accuracy of 100% or to the allowable +,- 2% deviation			
		Estimated Total Cost			320,880.00

Purpose: Verification and Calibration of Pumping Stations' flowmeters if in good condition.

Requested by:		Approved by:	 05/07
Signature :	EDILBERTO P. SANTOS	Engr. RONNIE B. LARGADO	
Printed Name	Department Manager, EOD	General Manager	
Designation :			