



REPUBLIC OF THE PHILIPPINES
CALUMPIT WATER DISTRICT

Bids and Awards Committee

M. Serrano St., Corazon Calumpit, Bulacan

Tel No.: (044) 675-1453 / 913-0079

Email address: calumpitwd@yahoo.com

BAC RESOLUTION NO. 2019-257

Re: Supply & delivery of Metering Pump

(For replacement of defective Hypo chlorinator at Central Pumping Station)

(Please see attached purchase request for item description)

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2019-10-013; Supply & delivery of Metering Pump (For replacement of defective Hypo chlorinator at Central Pumping Station);

WHEREAS, the members of the BAC agreed to adopt Section 52, Article XVI of RA 9184, which states the use of Shopping, a method of procurement of goods whereby the Procuring Entity simply requests for the submission of price quotations for readily available off-the-shelf goods or ordinary/regular equipment to be procured directly from suppliers of known qualifications. This method of procurement shall be employed in any of the following cases:


- a) When there is an unforeseen contingency requiring immediate purchase: *Provided, however,* that the amount shall not exceed the thresholds prescribed in Annex "H" of this IRR.
- b) Procurement of ordinary or regular office supplies and equipment not available in the Procurement Service involving an amount not exceeding the thresholds prescribed in Annex "H" of this IRR.

NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;


1. To recommend the use of Shopping for Purchase Request No. 2019-10-013.
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing findings;


RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, this 11th of October 2019.



EDILBERTO P. SANTOS
BAC Vice Chairman


MARICAR D. JOAQUIN
BAC Member

Engr. RONNIE B. LARGADO
General Manager, Head of the Procuring Entity
Approved on 10/14/19.


EMELY E. ECHEVARRIA
BAC Chairman


RONALDO D.C. TANTOCO
BAC Member


ESPERANZA L. CORTEZ
BAC Member



PURCHASE REQUEST

Entity Name: CALUMPIT WATER DISTRICT

Fund Cluster:

Office/Section : Enng'g & Operations Dept.		PR No.: <i>2019-10-03</i>			Date: 7-Oct-19
		Responsibility Center Code :			
Stock/ Property No.	Unit	Item Description	Quantity	Unit Cost	Total Cost
	unit	Metering Pump	1	90,910.00	90,910.00
		Model: KMF 0808 V 00 00			
		Max. Discharge Pressure: 8.0 bar (116 psi)			
		Stroke Frequency: 180spm (Digital Setting)			
		Troke Length: 0.3 - 1.0mm enable adjustment using dial			
		Rated Vpltage: 230 VAC (190 - 265 VAC)			
		Phase Frequency: 1 phase / 60Hz			
		Protection: IP65			
		Environmental Resistance : IEC Standard			
		Features: Digital Multifunction pump (Costant, Divide, Multiply, PPM, Batch, Volt, Ma, %, MLQ stand-by and flow sensor input, alarm output and level control			
		Materials: Diaphragm: Solid Teflon			
		Pump Head: PVDF Pumphead			
		Oring: VITON			
		Spring: Hasteloy C			
		Accessories: Complete with standard accessories with free level switch for automatic Stop on low level			
		Estimated Cost			90,910.00

Purpose: For replacement of defective Hypochlorinator at Central Pumping Station.

Requested by: Signature : Printed Name : Designation :	 EDILBERTO P. SANTOS Department Manager, EOD	Approved by:  Engr. RONNIE B. LARGADO General Manager
---	--	--