



REPUBLIC OF THE PHILIPPINES
CALUMPIT WATER DISTRICT

Bids and Awards Committee
M. Serrano St., Corazon Calumpit, Bulacan
Tel No.: (044) 675-1453 / 913-0079
Email address: calumpitwd@yahoo.com

BAC RESOLUTION NO. 2021-017

**Supply , Delivery, Repair & Testing of Generator Set
(Main Office Genset)**

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2021-01-22; **Supply & Delivery, Repair & Testing of Generator Set;**

WHEREAS, the members of the BAC agreed to adopt Section 53.9, Article XVI of RA 9184, which states the use of Small Value Procurement, a method of procurement of Goods, Infrastructure and Consulting Services where the amount involved does not exceed the thresholds prescribed in Annex "H" of this IRR: Provided, That in case of Goods, the procurement does not fall under shopping in Section 52 of this IRR.^(a)

The BAC shall prepare and send the RFQs/RFPs to at least three (3) suppliers, contractors or consultants of known qualifications. This, notwithstanding, those who responded through any of the required postings shall be allowed to participate. Receipt of at least one (1) quotation is sufficient to proceed with the evaluation thereof.

NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;

1. To recommend the use of Small Value Procurement for Purchase Request No. 2021-01-022.
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing findings;

RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, this 28th day of January 2021.

EMELY E. ECHEVARRIA
BAC Chairman

ESPERANZA L. BORTEZ
BAC Vice Chairman

EDILBERTO P. SANTOS
BAC Member

Engr. RONNIE B. LARGADO
General Manager, Head of the Procuring Entity
Approved on _____

RONALDO DC. TANTOCO
BAC Member

BENJO S. TORRES
BAC Member


JOB REQUEST

Entity Name: CALUMPIT WATER DISTRICT

Fund Cluster:

Office/Section : Enng'g & Operations Dept.		PR No.: <u>2021-01-022</u> Responsibility Center Code :	Date: Jan. 26, 2021		
Stock/ Property No.	Unit	Item Description	Quantity	Unit Cost	Total Cost
	lot	Supply, Delivery, Repair and Testing of Generator Set	1	100,740.00	100,740.00
		Engine Model: 1300 GC-E87TA 64			
		Engine Serial Number: WS 5263			
		Alternator Model & Serial Number: EO38-35 NLA			
		Action Taken:			
		- Visual check of Gen Set			
		- Check oil fuel and coolant level			
		- Test run off load			
		- Monitored running condition			
		- Composition sensor inactive			
		- Weak and tear composition sensor			
		Work to be done:			
		- Renew Engine Oil			
		- Replace Filters (Oil, Fuel, Air and Water)			
		- Replace CPS			
		Warranty:			
		- Supply of parts has six (6) months against factory defect but this excludes consumable items such as filters, belt, seals/joints etc.			
		- Repair/overhaul has three (3) months warranty			
		Estimated Total Cost			100,740.00

Purpose: For repair of Calumpit Water District Main office Generator Set.

Requested by:	 EDILBERTO P. SANTOS Department Manager, EOD	Approved by:	 Engr. RONNIE B. LARGADO General Manager
Signature :			
Printed Name :			
Designation :			