



BAC RESOLUTION NO. 2021-233

Supply, Delivery , Installation, Testing & Commissioning of Octave Ultrasonic Meters
(replacement of defective mechanical flowmeter at Tata Pading PS)

WHEREAS, the Bids and Awards Committee is hereby instructed to act upon the CWD with Purchase Request No. 2021-11-003 ; **Supply, Delivery , Installation, Testing & Commissioning of Octave Ultrasonic Meters** (replacement of defective mechanical flowmeter at Tata Pading PS);

WHEREAS, the members of the BAC agreed to adopt Section 52, Article XVI of RA 9184, which states the use of Shopping, a method of procurement of goods whereby the Procuring Entity simply requests for the submission of price quotations for readily available off-the-shelf goods or ordinary/regular equipment to be procured directly from suppliers of known qualifications. This method of procurement shall be employed in any of the following cases:

- a) When there is an unforeseen contingency requiring immediate purchase: *Provided, however,* that the amount shall not exceed the thresholds prescribed in Annex "H" of this IRR.
- b) Procurement of ordinary or regular office supplies and equipment not available in the Procurement Service involving an amount not exceeding the thresholds prescribed in Annex "H" of this IRR.

NOW THEREFORE, We, the members of Bids and Awards Committee, hereby RESOLVE as it is hereby RESOLVED;

1. To recommend the use of Shopping for Purchase Request No. 2021-11-003 ;
2. To recommend for approval by the General Manager of the Calumpit Water District the foregoing finding;

RESOLVED, at the CWD Office, Corazon, Calumpit, Bulacan, this 9th day of November 2021.



EMELY E. ECHEVARRIA
BAC Chairman



ESPERANZA L. CORTEZ
BAC Vice Chairman




EDILBERTO P. SANTOS
BAC Member



RONALDO D.C. TANTOCO
BAC Member



BENJO S. TORRES
BAC Member





Engr. RONNIE B. LARGADO
General Manager, Head of the Procuring Entity

PURCHASE REQUEST

Entity Name: CALUMPIT WATER DISTRICT

Fund Cluster:

Office/Section : Enngg & Operations Dept.		PR No.: <u>2021-11-003</u> Responsibility Center Code :		Date: Nov. 03, 2021	
Stock/ Property No.	Unit	Item Description	Quantity	Unit Cost	Total Cost
		SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF:			
	Unit	OCTAVE ULTRASONIC METERS Size: DN 50 (2 inches)	1	155,545.00	155,545.00
TECHNICAL SPECIFICATIONS:					
Max. Working Pressure: 16 Bar					
Liquid Temperature: 0.1 up to 50 deg C					
Precision Class: ISO 4064 rev. 2005, Accuracy Class 2					
Configuration: Compact - The Display is built in to the unit					
Power Source: 2D Size Li-battery: up to 15 years lifetime					
Environmental Protection: IP68, Ambient Operation Temp. - 25 Dec C up to +55 Deg C					
Volume Display Options: 1. Net (Forward less reverse)					
2. Forward only					
3. Reverse only					
4. Forward and reverse alternating					
Data Logger: Volumes and alarms data (48kv, 430 data points)					
Connections: 1½ - 2" threaded with coupling NPT/BSP					
2" - 12" flanged: flanges according to ISO, BS 10 and ANSI 150					
Severity Levels: Mechanical Class M1					
Electromagnetic Environment Class E1					
Pressure Loss: 0.16 bar					
ADDITIONAL DOCUMENTS					
1. Brochure					
2. Dealership Certificate					
3. Exclusive Distributorship					
Estimated Cost					155,545.00
Purpose: For replacement of defective mechanical flowmeter at Tata Leon PS.					
Requested by:			Approved by:		
 EDILBERTO P. SANTOS Department Manager, EOD			 Engr. RONNIE B. LARGADO General Manager		